



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail      wsdinfo@wsd.gov.hk

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 8 ) in WSD 3321/17 Pt.1 T/J(1160)

11 April 2018

VOLA A/S  
Room 1801A, 18/F  
93-103 Wing Lok Street,  
Sheung Wan, Hong Kong

(Attn.: Ms Jytte RASMUSSEN)

Dear Madam,

### Approval of "VOLA" Flow Control Valves

Your letter dated 16 August 2017 and subsequent submission received by this department on 26 March 2018 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

**Name of Manufacturer:** Vola A/S

**Country of Origin:** Denmark

**Brand:** Vola

**Details of Fittings:** Wall mounted, shower, flow control valve (either stainless steel or brass bodies in a variety of finishes) incorporating a quarter turn ceramic disc headwork with a single lever operating member. Maximum working pressure 10.0 bar. Maximum working temperature 65°C.

**Model:** S10-xx  
(where "xx" denote the code of finishes)

**Size:** ½" BSP (M)

**Marking:** VOLA on body

**WRAS Approval Number:** 1711709

**Installation Requirements:** R001

**Expiry Date:** 30 November 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only